PINE COVE WATER DISTRICT
OPERATIONS REPORT
August 12, 2026

1. Production:

A.	July 2026	3,280,743 Gallons
	July 2025	3,304,750 Gallons
	July 2024	3,504,049 Gallons
B.	2-month Production (June/July)	6,192,190 Gallons
	Accounted for	5,434,101 Gallons
	Water Loss	12.2%

C. Static Well #10 – 107.3 feet
Down by 3.2 feet

2. Other Items:
   a. Metering System - Expecting to get the new transmitter this month. As soon as they arrive, we will begin to swap them out.
   b. Vehicles/Equipment - Received the 2 new back up generators. We are in the process of upgrading the 2 locations with weather-tight connections.
   c. System Maintenance - Hydrant, valve exercising and maintenance has been completed as well as flushing of the system.
   d. Office Update - We've worked with Current to get the accounts receivables current per auditors recommendation. Reports are understood moving forward and we feel comfortable moving forward with Current being our billing provider at this time. Initial review of adjustments were done by auditors who stated they "have a good feeling about this year".
   e. Audit - Scheduled for August 24th; received checklist of requested documents, Jennifer & Toya are working on the pre-submissions.

Jeremy Potter, General Manager